




4. CONDUITS SHALL NOT EXTEND INTO VAULT MORE THAN 3", CONDUITS SHALL BE 4" ABOVE BOTTOM OF VAULT WITH A MINIMUM OF 36" OF COVER.



5. ALL ENTRY HOLES, AROUND CONDUITS, IN THE VAULT SHALL BE GROUTED TO A SMOOTH FINISH TO PREVENT BACKFILL MIGRATION INTO VAULT CAVITY.
6. VAULTS SHALL BE CLEARED OF ALL FOREIGN MATERIAL.
7. MULTIPLE CONDUITS SHALL MAINTAIN AT LEAST A TWO INCH SEPARATION WHEN ENTERING VAULTS.



HORIZONTAL



TRIANGLE

SHEET: 2 of 2



## VAULT CONDUIT INSTALLATION NOTES AND DETAILS

DATE	REVISION	APPROVED			
7/13/2012	REVISED TO UPDATE CURRENT STANDARD	JCD			
			DATE	2/10/99	
			DRAWN	JDW	APPROVED DJE
					SPEC NO. VCD2