



- NOTE:
1. PLACE SIX-INCH SCHEDULE 40 H.D. GALVANIZED STEEL POSTS FILLED WITH CONCRETE A MAXIMUM OF SIX FEET APART ON ALL SIDES EXPOSED TO VEHICLES.
 2. ALL CONCRETE SHALL HAVE A MINIMUM COMPRESSIVE STRENGTH OF 3000 psi AFTER 28 DAYS.
 3. BARRIER POST INSTALLATION SHALL BE IN UNDISTURBED EARTH. HOWEVER THE AREA BETWEEN THE VAULT WALL AND BARRIER HOLE MAY BE FILLED WITH 3/4" MINUS COMPACTED GRAVEL IF THREE FEET OF UNDISTURBED AREA IS NOT AVAILABLE AFTER THE VAULT IS SET.
 4. MARK TOP OF POSTS WITH TWO THREE-INCH WARNING BANDS OF CONTRASTING COLORS. POSTS MAY BE PAINTED AT OPTION OF CUSTOMER.
 5. IN LIGHT TRAFFIC AREAS, A POWER SCREW BARRIER POST IS ACCEPTABLE.
 6. CONSULT MW&L FOR APPROVAL IF DIMENSION CHANGES ARE NECESSARY.



PAD-MOUNTED TRANSFORMER BARRIER POST INSTALLATIONS

DATE	REVISION	APPROVED	DATE	APPROVED	SPEC NO.
7/13/2012	REVISED TO UPDATE CURRENT STANDARD	JCD	12/14/00		
			DRAWN JDW	APPROVED DJE	PBP1