



OLD CASTLE  
WITH  
PADMOUNT LID  
OR APPROVED EQUAL

NOT TO SCALE

PART #	EACH	ASSEM. ID	MATERIAL
212501	1	VT44	UG VAULT 4'x4'x4'-OLD CASTLE #444LA
212513	1	VP44	UG VAULT PAD 4'x4' (FOR 25,50,75,100 KVA)-OLD CASTLE #44-2125



1Ø

7.2/12.5 KV  
VAULT, TRANSFORMER  
4'x4'x4'  
SINGLE PHASE

DATE	REVISION	APPROVED	DATE	APPROVED	SPEC NO.
7/13/2012	REVISED TO UPDATE CURRENT STANDARD	JCD	2/10/99	DJE	VT44