


TOP SECTION



OLD CASTLE WITH LOCKING STEEL COVER AND PADMOUNT (SEE VTL1 & VTL2) OR APPROVED EQUAL

NOT TO SCALE

PART #	EACH	ASSEM. ID	MATERIAL
212502	1	VL44	UG VAULT LID- OLD CASTLE #44-332P
212504	1	V64	UG VAULT 6'x4'x4'- OLD CASTLE #644LA
*	1	VP*	UG VAULT, TRANSFORMER PAD - BOLLARDS (IF REQUIRED)



3 ϕ

7.2/12.5 KV
VAULT, TRANSFORMER PAD & LID
6'x4'x4'
THREE PHASE

DATE	REVISION	APPROVED	DATE	APPROVED	SPEC NO.
7/13/2012	REVISED TO UPDATE CURRENT STANDARD	JCD	2/10/99	DJE	VT64