


NOTES:

1. Air gap protection may be used in lieu of mechanical backflow protection, with MW&L approval.
2. All air gaps are measured from the bottom of the supply line to the top of the overflow rim of the sink or basin that is being filled. The air gap shall be twice the diameter of the supply line, but in no case less than 1" and in accord with Oregon Plumbing Specialty Code.
3. If the supply line is cut at an angle, the point closest to the basin is used for measurement.
4. If the supply line is reduced at the opening, the diameter used for the air gap is taken at the largest portion of the supply piping.
5. There shall be no extensions or attachments on the open end of the supply piping. Any such extensions or attachments will void the air gap protection.

		<h2 style="margin: 0;">AIR GAP BACKFLOW PROTECTION</h2>		
DATE	REVISION			
		DATE 12/8/14		
		DRAWN SLW	APPROVED WSC	SPEC NO. BF-AG