


**NOTES:**

1. Atmospheric Vacuum Breaker (AVB) shall have product and material approval under the Oregon Plumbing Specialty Code for non-testable devices. Devices shall be approved by the State of Oregon.
2. AVB shall be installed in an upright position with a minimum of 6" above the highest piping or outlet that it serves.
3. AVB shall not be installed in an area where flooding is a possibility.
4. AVB shall not be installed where dusty, corrosive, or toxic atmospheres are present. No chemical or fertilizer may be introduced through an irrigation system equipped with an AVB.
5. AVB shall have absolutely no means of shut-off on the downstream (discharge) side of the device, and shall not be subject to back pressure.
6. AVB cannot be under constant pressure for more than 12 hours in any 24-hour period.

NOT TO SCALE



## ATMOSPHERIC VACUUM BREAKER (AVB)

		<h2 style="margin: 0;">ATMOSPHERIC VACUUM BREAKER (AVB)</h2>		
DATE	REVISION			
		DATE 12/8/14		
		DRAWN SLW	APPROVED WSC	SPEC NO. BF-AVB