


NOTES:

1. Double Check Detector Assembly:
  - a. is required on fire service lines;
  - b. shall be on the State of Oregon list of approved assemblies and shall include factory supplied shut-off valves;
  - c. shall be installed in a location approved by MW&L, near MW&L's point of service;
  - d. may be installed vertically, provided the assembly is specifically listed for that orientation in the State of Oregon list of approved assemblies.
2. Detector meter to measure in cubic feet.
3. Detector meter supplied as part of the assembly.
4. Assemblies installed below ground level shall have watertight, threaded plugs or caps installed on test cocks. The assembly shall not be subject to continuous immersion.
5. All clearances apply to in-building, and vault installations.
6. Box shall be placed upon compacted 3/4 - minus gravel.
7. Contact the McMinnville Fire Department to determine if FDC is required:  
When fire hydrants are located downstream of the DCDA the FDC shall be plumbed directly to the fire sprinkler riser, above all control valves. DCDA's that serve fire protection systems shall be electronically supervised, not chained.
7. Shall be protected from freezing when necessary.

---

Permanent water service will not be granted until an initial Backflow Test Report is received by MW&L. Annual testing of assembly is required.

		<b>DOUBLE CHECK DETECTOR ASSEMBLY 2"</b>	
(REQUIRED ON FIRE SERVICE LINES)			
DATE	REVISION		
		DATE 09/20/16	SHEET NO. 2 OF 2
		DRAWN SLW	APPROVED WSC
			SPEC NO. DCDA-2A