



FOR CLEARANCES FROM SANITARY
SEWER REFER TO OAR 333-061-0050(9)

NOT TO SCALE



WATER MAIN CLEARANCES FROM OTHER UTILITIES

3' HORIZONTAL
1' VERTICAL

DATE	REVISION

DATE	12/8/14		
DRAWN	SLW	APPROVED	WSC
		SPEC NO.	TCLR