


- NOTES:
1. SEE MW&L SPEC V577, V676, V687 & V5106 FOR VAULT SIZING, LADDER AND DOOR REQUIREMENTS.
  2. METER AND MAINTENANCE BY-PASS SHALL BE SAME SIZE AND APPROVED BY MW&L.
  3. 3" METERS SHALL BE PLUMBED WITH 4" DUCTILE PIPE, VALVES & BYPASS.
  4. METER BY-PASS ISOLATION VALVE SHALL HAVE A WHEEL GATE HANDLE
  5. METER ISOLATION VALVES SHALL BE FLG x MJ WITH MEGALUG RESTRAINTS.
  6. SEAL ALL VAULT PENETRATIONS WITH WATER-TITE GROUT.
  7. DUCTILE IRON PIPE SHALL BE USED THROUGHOUT THE VAULT.

NOT TO SCALE

		<h2 style="margin: 0;">WATER SERVICES</h2> <h3 style="margin: 0;">3" AND LARGER</h3>			
DATE	REVISION				
		DATE	12/10/14		
		DRAWN	SLW	APPROVED	WSC
				SPEC NO.	WMS-3